

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



## LISTING SERVICE

**LISTING No.** 7165-0992:0501

Page 1 of 2

**CATEGORY:** 7165 -- FIRE ALARM CONTROL UNIT (COMMERCIAL)

**LISTEE:** Napco333 Bayview Avenue, Amityville, NY 11701  
Contact: David Wagner (631) 842-9400 Fax (631) 842-2726  
Email: dwagner@napcosecurity.com

**DESIGN:** Models FL-32FACP, FL-96FACP, FL-128FACP, FL-255FACP; FL-32FACP-A, FL-96FACP-A, FL-128FACP-A, FL-255FACP-A, \*FL-32FACP-LTEAI, \*FL-96FACP-LTEAI, \*FL-128FACP-LTAI, \*FL-255FACP-LTAI, \*FL-32FACP-LTEVI, \*FL-96FACP-LTEVI, \*FL-128FACP-LTVI, \*FL-255FACP-LTVI, \*FL-32FACP-LTEAS, \*FL-96FACP-LTEAS, \*FL-128FACP-LTAS, \*FL-255FACP-LTAS \*FL-32FACP-LTEVS, \*FL-96FACP-LTEVS, \*FL-128FACP-LTVS and \*FL-255FACP-LTVS fire alarm control units. Automatic, manual, waterflow and sprinkler supervisory service, local, remote station (PPU) and central station (PPU). Models with Suffix "A" indicate integral GSM radio and models without suffix "A" integral CDMA radio. All Models may be followed by three alphanumeric characters. \*Models with suffix LTEVS/LTEAS/LTVS/LTSA are Sole Path radios. \*Models with suffix LTEVI/LTEAI/LTVI/LTAI are Dual Path radios.

System components:

GEMC-HSKIT1416, HSKIT1425; Enclosure  
GEMC-32MB, GEMC-96MB, GEMC-128MB, GEMC-255MB; Main Boards  
GEMC-PS24V4A, GEMC-PS24V7A; Power Supply  
GEMC--FW-SLC; Fire Signaling Line Circuit Modules  
GEMC-F8ZCPIM; Zone Expander Modules  
GEMC-24VR; 24V Output Module  
GEMC-FK1; Keypad  
9SLECDMAIPSLD or 9SLEGSMDDPPSLD; SLE Dual Path Communicators

Refer to listee's data sheet for detailed product description and operational considerations.

**RATING:** 120 VAC, 12 and 24 VDC

**INSTALLATION:** In accordance with listee's printed installation instructions and applicable codes and ordinances, NFPA 72 and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee's name, model number, electrical rating and UL label.

**APPROVAL:** Listed as fire alarm control units for use with separately listed compatible initiating and indicating devices. Refer to manufacturer's Installation Manual for details.

**NOTE:** For Fire Alarm Verification Feature, the maximum Retard/Reset/Restart must be adjusted to

\*Rev 10-03-19 gt



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2019**

Listing Expires **August 29, 2020**

Authorized By: **DAVID CASTILLO, M.E., F.P.E., Program Coordinator**  
*Fire Engineering Division*

30 sec. or less.

\*Rev 10-03-19 gt



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2019**

*Listing Expires* **August 29, 2020**

Authorized By: **DAVID CASTILLO, M.E., F.P.E., Program Coordinator**  
*Fire Engineering Division*